

**Abstract for Verification Test Protocol for Microbial Decontamination IAQ (Indoor Air Quality)  
(SOP\_QA\_054) Effective Date: 11/9/2020**

**Customer :** YDROPSIKTIKI PAPATHANASIOU SA

**Equipment Name:** PURE 80/PRO

**Installation Area:** OFFICE ROOM OF 100m<sup>2</sup> (3 m height)

**Duration:** 45 min.

**Compliance:**

1. **WHO / EUROPE** "Environmental (non industrial guidelines developed in 1987 & in 1999 by the WHO office for Europe (Denmark). Intended for application both to indoor & outdoor exposure.
2. **ANSI / ASHRAE** Standard 62.1 "Ventilation for Acceptable Indoor Air Quality"

**OEBD (average 5 points) Before decontamination: 2.047**

**OEBD (average 5 points) After decontamination: 600**

The results of microbial decontamination tests for 100m<sup>2</sup> of room are **acceptable according to WHO limits.**



**Ioannis Manolopoulos**  
Validation Engineer  
Qualitech Engineering & Compliance